

TO ALL BIDDERS

ADDENDUM NO. 1 AND CLARIFICATION OF TENDER DOCUMENTS

TENDER NO: KWS/ONT/B&F/32/2026-2027
PROPOSED CONSTRUCTION AND INSTALLATION OF TROPHY ROOM DISPLAY RACKS,
INCLUDING THREE (3) SUMP PITS AND SUBMERSIBLE PUMPS AT KWS
HEADQUARTERS
(RESERVED FOR YOUTH AND WOMEN)

Pursuant to Section 75 of the PPADA (2015) and clauses 5 and 19 of the tender documents, Kenya Wildlife Service wishes to make the following clarification on the above tenders: -

1. Purpose

This Addendum corrects inconsistencies and leftover template text in the tender document issued on Tuesday 6th October 2026. Where this Addendum conflicts with the tender document, this Addendum prevails.

S/No.	Item	Delete / disregard	Insert / apply
1.	Works	Contents entry naming the Jomo Kenyatta Public Beach Triumphal Gate.	The works are the trophy room display racks, three sump pits and three submersible pumps at KWS Headquarters, Lang'ata Road.
2.	Submission	The closing date Tuesday 13 th October, 2026 1100hrs	Extended to Wednesday 21 st October, 2026 1100hrs
3.	Period	Nine (9) months in the Special Conditions.	Four (4) months, as stated in the invitation to tender.
4.	Contract price	Clause 14.1.1 figure of KSh 10,373,178.20.	The prescribed figure should be "IGNORED" . Each bidder inserts its own tender sum. Clause 14.1.1 will be completed after award with the accepted tender sum.
5.	Representative	Clause 4.3 name, Mr Mohamed Amin Hussein Ali.	The contractor's representative will be the person nominated by the successful bidder. "IGNORE" the name mentioned
6.	Reservation	Any reading that a bidder must hold both a Youth and a Women certificate.	A valid AGPO certificate for Youth or for Women is acceptable.
7.	Financial test	The conflicting tests on	Minimum Average annual construction

S/No.	Item	Delete / disregard	Insert / apply
		page 28 and pages 33 to 35.	turnover KSh 1,000,000. Average annual turnover KSh 13,000,000 over three years. Two similar contracts of at least KSh 2,000,000 each.
8.	Non-performance	The five-year test where it conflicts with the qualification form.	Non-performance is assessed over the last three years.
9.	Bidder registration	A requirement for CR12 only, where the data sheet allows CR13.	CR12 or CR13 is acceptable and ID copies of the directors.
10.	Pagination	Missing	All the pages of the bid document MUST be chronologically serialized from cover page to the last page in THE FORMAT 1, 2, 3.....
11.	VAT	The instruction to allow VAT at 1.19.	VAT at 16 percent. The tender sum is VAT inclusive.
12.	Timber	24,125 feet of 200 x 25 mm hardwood, read as a fixed quantity.	200 x 25 mm seasoned hardwood. Quantity is provisional and will be remeasured. Bidders price the measured quantity and state the quantity priced.
13.	Steel	Lengths with no length stated.	Each length is a standard 6 m piece, unless the site measure shows otherwise. Quantity is provisional.
14.	Pumps	The words 'as per the descriptions provided', where no description exists.	As per attached specifications
15.	Site visit	The spelling HEADQUATERS.	Mandatory site visit: Thursday 15 th October 2026, 11:00 a.m., KWS Headquarters reception, Lang'ata Road. Certificate remains mandatory.

All other terms and conditions of the tender remain the unchanged.

To obtain further information on this tender kindly use the following email address:

hps@kws.go.ke



DEPUTY DIRECTOR, SUPPLY CHAIN MANAGEMENT

FOR: DIRECTOR GENERAL

MOTOR

Pumps are supplied with two pole single phase squirrel cage motors with integral thermal overload protection and can be directly connected to the mains through a 10A fuse or MCB (13A for 1.5kW motor)

Enclosure Class:IP68

Insulation Class:F

Voltage: 1x240

Speed: 2850rpm

FEATURES & BENEFITS

OPERATING CONDITIONS

Pumped Liquid: Thin, clean, chemically non-aggressive liquids

Max. Fluid Temperature: +40°C

Max. Ambient Temperature: +40°C

Min Immersion Depth:10m

Max. Particle Size: <1.1kW, 3.3mm, >1.5kW, 5.5mm

SPECIFICATIONS

PUMP DATA

Model	Power		Current(A)	Dimensions(mm)		DN(")	Weight(kg)
	kW	HP		W	H		
DWY370	0.37	0.5	2.8	195	340	1	7
DWY550	0.55	0.75	4.2	235	380	2	10
DWY750L	0.75	1	6.1	230	390	1.5	11
DWY750H			6.3	235	390	1	11
DWY1500	1.5	2	9.1	270	465	3	20

SAFETY NOTE

Electrical installations should be carried out by a qualified technician.

Handle chemicals with care as they are hazardous


Nguyễn Thị Bích Ngọc.