






LEGEND		
Qty	KEY	DESCRIPTION
18	 DC	Dome Camera
10		Bullet Camera
18		1g1w switch
9		1g2w switch
5		2g2w switch
6		Double Pole Switch
30		1x1200mm 36w IP 65 LED Batten fitting
11		Circular 20W LED IP65 lamp(Wet Areas)
26		Circular 20W LED lamp(passage)
12		LED High Bay Lighting
7		IP65 50w LED Flood Light
32		Twin Data faceplate
12		Wireless Access Point
5		Fire Alarm Sounder
5		break glass
1		Fire Alarm Panel
20		smoke detector
6		Exit light
44		13A Twin Socket Outlet
2		Consumer Unit
1		
1		Earthing Manhole

NOTES				
1) Drawing Shall be read together with Architects,Civil Engineers and Mechanical Engineers Drawings. Any discrepancies MUST be reported to the Engineers. 2) All samples shall be approved before Installation commences. 3) This drawing must be checked against existing site conditions and any discrepancies MUST be reported to the Engineers. 4) All cables should be copper 5) All lighting switches shall be mounted at the height of 1350mm a.f.f.l. unless otherwise stated. 6) All socket outlets shall be mounted at the height of 300mm a.f.f.l. unless otherwise stated. 7) All distribution boards and consumer units shall be mounted at the height of 1800mm a.f.f.l. unless otherwise stated. 8) All lighting circuits shall be 2x1.5 sq. mm PVC SC + 1.5 sq. mm e.c.c copper cables unless otherwise specified. 9) All ring mains circuits shall be 2x2.5 sq. mm PVC SC + 2.5 sq. mm e.c.c copper cables unless otherwise specified.				
REVISIONS				
Rev No.	DATE	BY	DESCRIPTION	SIGNATURE
CLIENT NG-CDF - MUKURWE-INI, P.O BOX MUKURWE-INI. SIGN				
PROJECT PROPOSED KANGURWE POLICE STATION				
DRAWING TITLE ELECTRICAL LEGEND/SYMBOLS				
SCALES		DRG NO		
NTS		E/ 04.		
		NAME		SIGNATURE
DESIGNED		D.M.G		SEPTEMBER, 2026
DRAWN		D.M.G		SEPTEMBER, 2026
CHECKED		R.W.O	QS. K. NGANG'A	SEPTEMBER, 2026
MINISTRY OF LANDS, PUBLIC WORKS, HOUSING AND URBAN DEVELOPMENT				
 REPUBLIC OF KENYA		 STATE DEPARTMENT FOR PUBLIC WORKS Public Works Makes Kenya Work		