



SPECIFICATION FOR AEROSOL CAN HOLDER FOR LIVE-LINE WORK

A Document of the Kenya Power & Lighting Plc

OCTOBER, 2026

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 1 of 18

Table of Contents

0.1 Circulation List.....	2
0.2 Amendment Record.....	3
0.3 Foreword.....	4
1. SCOPE.....	5
2. NORMATIVE REFERENCES	5
3. DEFINITIONS AND ABBREVIATIONS	5
3.1 Abbreviations	5
3.2 Definitions	6
4. REQUIREMENTS	6
4.1 Service Conditions.....	6
4.2 Design and Construction	7
4.3 Holder Body and Insulating Parts.....	7
4.4 Can Holding Arrangement	7
4.5 Remote Actuation.....	8
4.6 Nozzle Positioning.....	8
4.7 Weight and Dimensions	8
4.8 Accessories.....	8
4.9 Technical Particulars	8
5. TEST REQUIREMENTS.....	9
6. MARKING AND PACKING.....	10
6.1 Marking	10
6.2 Packing	10
7. WARRANTY	11
8. TRAINING.....	11
8.1 Training at the manufacturer's premises	11
8.2 Local Training	11
APPENDICES.....	13
A: TESTS AND INSPECTION (Normative).....	13
B: QUALITY MANAGEMENT SYSTEM (Normative)	13
C: TECHNICAL DOCUMENTATION (Normative).....	13

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 2 of 18

0.1 Circulation List


Copy No.	Copy Holder
1	Manager, Transmission
2	Senior Engineer, Sub-transmission

REVISION OF KPLC STANDARDS

To keep abreast of progress in the industry, KPLC Standards shall be regularly reviewed. Suggestions for improvements to approved Standards, addressed to the Manager, Standards Department, are welcome.

© Kenya Power & Lighting Co. Ltd.

Users are reminded that by Section 25 of the Copyright Act, 2001 (Revised 2014) Cap 130 of the Laws of Kenya, copyright subsists in all KPLC Standards and except as provided under Section 26 of this Act, no KPLC Standard produced by KPLC may be reproduced, stored in a retrieval system by any means without prior permission from the Managing Director & CEO, KPLC.


Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 3 of 18

0.2 Amendment Record

Rev No.	Date (YYYY-MM-DD)	Description of Change	Prepared by (Name & Signature)	Approved by (Name & Signature)
0	2026-10-19	New issue	Eng. Alistair Akute	Eng. George Korir

----- THIS SPACE IS LEFT BLANK -----

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 4 of 18

0.3 Foreword

This specification has been prepared by the Transmission Department in collaboration with the Live Line Section, of The Kenya Power and Lighting Company Plc. The specification lays down requirements for the Aerosol Can Holder for Live-Line Work. It is intended for use by KPLC to procure insulated holders that fit on the universal end fitting of a live-line (hot) stick, carry a commercially available aerosol spray can, and allow the operator to spray the can remotely at energized line hardware, such as connectors, clamps and insulator surfaces, from a safe distance.

Live-line working avoids planned outages, which shortens the time customers are without supply and improves network performance indices such as SAIDI (System Average Interruption Duration Index). Spray products approved by KPLC (for example dielectric-safe contact cleaner, silicone, corrosion inhibitor or lubricant) help to extend the life of line hardware and to reduce faults caused by corrosion and contamination.

Because the holder is carried on an insulating stick close to energized parts, the safety of the crew depends on its insulating materials, secure retention of the can, and reliable remote actuation. Aerosol products can also be conductive or flammable when sprayed, so only products approved by KPLC may be used. This specification therefore stipulates the minimum requirements for the design, materials, performance, testing and documentation of aerosol can holders acceptable for use on the KPLC power network.

There are no other specifications in this series.

It shall be the responsibility of the suppliers and manufacturers to ensure that the offered design is of the highest quality and guarantees excellent service to KPLC, good workmanship and good engineering practice in the manufacture of the aerosol can holder.

Users of Kenya Power specifications are responsible for their correct interpretation and application.

The following are members of the team that developed this specification:

Name	Department	Signature	Date
Nicodemus Otoré	Transmission		19/10/2026
Callen Buruchara	Distribution/ Live Line		19/10/2026

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 5 of 18

1. SCOPE

- 1.1 This specification covers technical requirements for the aerosol can holder that shall be used by KPLC live-line teams, mounted on live-line sticks, to spray approved products onto energised line equipment on 66 kV to 220 kV overhead lines.
- 1.2 The specification covers requirements for design, inspection and tests, packing, warranty and training for the aerosol can holder and its associated accessories.


2. NORMATIVE REFERENCES

The following standards contain provisions which, through reference in this text, constitute provisions of this specification. For dated editions the cited edition will apply; for undated editions the latest edition of the referenced document shall apply.

Standard	Title
IEC 60832 (Parts 1 & 2)	Live working – Insulating sticks and universal tool attachments
IEC 60855-1	Live working – Insulating foam-filled tubes and solid rods – Part 1: Tubes and rods of a circular cross-section
IEC 61477	Live working – Minimum requirements for the utilization of tools, devices and equipment
IEC 60060-1	High-voltage test techniques – Part 1: General definitions and test requirements
IEC 60243-1	Electric strength of insulating materials – Test methods – Part 1: Tests at power frequencies
IEC 60112	Method for the determination of the proof and the comparative tracking indices of solid insulating materials
IEC 60068	Environmental testing
IEC 60815	Selection and dimensioning of high-voltage insulators intended for use in polluted conditions
ASTM F711	Fiberglass-reinforced plastic (FRP) rod and tube used in live-line tools
ISO 4892-2	Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps
IEEE 978	Guide for in-service maintenance and electrical testing of live-line tools
ISO 9001	Quality Management Systems – Requirements
ISO/IEC 17025	General requirements for the competence of testing and calibration laboratories

3. DEFINITIONS AND ABBREVIATIONS

For the purpose of this specification, the definitions and abbreviations given in the reference standards shall apply together with the following.

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 6 of 18

3.1 Abbreviations

Abbreviation	Meaning
ASTM	American Society for Testing and Materials
CTI	Comparative Tracking Index
FRP	Fibre-Reinforced Plastic
GTP	Guaranteed Technical Particulars
IEC	International Electrotechnical Commission
IEEE	Institute of Electrical and Electronics Engineers
ISO	International Organization for Standardization
Kg	Kilogram
KPLC	Kenya Power and Lighting Company Plc
kV	Kilovolt
MAD	Minimum Approach Distance
mL	Millilitre
N	Newton
QAP	Quality Assurance Plan
SAIDI	System Average Interruption Duration Index

3.2 Definitions

Aerosol can holder: an insulating device, mounted on the universal end fitting of a live-line stick, that holds an aerosol spray can and allows the operator to actuate the spray valve remotely.

Universal attachment: the standard end fitting of a live-line stick that allows heads and tools to be interchanged, in accordance with IEC 60832.


Approved spray product: an aerosol product that has been approved in writing by KPLC for use on energised line equipment, being non-conductive and of acceptable flammability.

4. REQUIREMENTS

4.1 Service Conditions

4.1.1 The aerosol can holder shall be suitable for outdoor use in tropical areas and in harsh climatic conditions including areas exposed to:

- Altitudes of up to 2200 m above sea level;
- Humidity of up to 90%;
- Average ambient temperature of +30 °C with a minimum of -1 °C and a maximum of +40 °C;
- Isokeraunic levels of up to 180 thunderstorm days per year;
- Pollution (IEC 60815) Very Heavy: Class IV.

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 7 of 18

- 4.1.2 The holder shall be used on live-line sticks at 66 kV, 132 kV and 220 kV overhead lines at 50 Hz. The network voltage on which the holder will be used shall be specified for each tender.

4.2 Design and Construction


- 4.2.1 The aerosol can holder shall be designed, manufactured and tested in accordance with IEC 60832, IEC 60855-1 (for FRP parts), IEC 61477 standard.
- 4.2.2 The holder shall consist of the following main parts: the holder body and arm, a can cradle with an adjustable retaining strap or clamp, a remote actuator for the spray valve, a nozzle positioning arm, and a universal end fitting.
- 4.2.3 The holder shall fit the universal end fitting of KPLC live-line sticks and shall be fitted and removed without tools, by a lineman wearing gloves.
- 4.2.4 All surfaces shall be free from sharp edges and burrs. Metal parts shall be of stainless steel or anodized aluminium. No metal part or linkage shall bridge the effective insulating length of the stick or the actuating cord.
- 4.2.5 The holder shall not reduce the effective insulating length of the stick on which it is mounted. The overall length shall not to exceed 14 in (356 mm) and shall be designed so that no conductive portion reduces the stick's effective insulating length" aligns with existing commercial tools that satisfy the requirement

4.3 Holder Body and Insulating Parts

- 4.3.1 The body and arms shall be made of epoxy-glass FRP complying with IEC 60855-1 or ASTM F711, or of high-impact, UV-stabilised engineering polymer. Polymer parts shall have a dielectric strength of not less than [15] kV/mm (IEC 60243-1) and a comparative tracking index of not less than [600] (IEC 60112).
- 4.3.2 The insulating parts shall withstand 100 kV (rms, 50 Hz) per 300 mm of length for 1 minute without flashover, puncture or perceptible heating (IEC 60060-1). For parts shorter than 300 mm, the test voltage shall be proportional to the length, and the test shall be repeated on the holder mounted on a stick.
- 4.3.3 The surface shall be smooth, hydrophobic and resistant to UV and to the solvents and propellants in approved spray products. The moisture absorption of polymer parts shall not exceed [0.5] %.
- 4.3.4 Where an operating cord is used, it shall be a poly-dacron insulating rope able to withstand upto 220kV and of diameter not less than [6] mm.

4.4 Can Holding Arrangement

- 4.4.1 The holder shall accept standard aerosol cans of 400 mL (14 oz) capacity, of diameter [50 mm to 70 mm] and height up to [260 mm] including the cap. The tenderer shall state the range of can sizes that the holder accepts.

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 8 of 18

4.4.2 The can shall be secured by a clamp with a positive lock that holds the can against wind, vibration and shock. A secondary retention device (safety catch or lanyard) shall prevent the can from falling if the primary retention fails. The retaining force shall be not less than [100 N] in the axial direction.

4.4.3 A can shall be replaceable by hand, without tools, by a lineman wearing gloves.

4.5 Remote Actuation

4.5.1 The spray valve shall be operated remotely by an insulating pull cord or lever mechanism that can be operated from the ground or from the bucket. The force needed to operate the actuator shall not be more than [40 N].

4.5.2 The actuator shall be spring-returned, so that spraying stops as soon as the operator releases it. A lock or safety pin shall prevent accidental discharge during transport and lifting.

4.5.3 Cord guides or clips shall be provided to keep the actuating cord clear of the stick and of the conductor.

4.5.4 The actuator shall withstand not less than [10,000] operating cycles without failure.

4.6 Nozzle Positioning

4.6.1 The nozzle shall be adjustable over an angle of at least [0° to 90°] relative to the axis of the stick, and shall be locked positively in the chosen position. The angle shall be adjustable by hand, wearing gloves, before the stick is raised.

4.6.2 The holder shall allow an extension nozzle or straw to be fitted, and shall be fitted with a spray guard to reduce overspray towards the operator.


4.7 Weight and Dimensions

4.7.1 The weight of the holder shall not exceed 1.0 kg without the can. The overall length shall not exceed 400 mm. The weight shall be balanced so that the stick can be handled easily at full reach.

4.8 Accessories

4.8.1 The following shall be supplied with each holder:

- Two (2) spare retaining straps;
- One (1) set of spare springs, pins and fasteners;
- One (1) operating cord of not less than [10] m with cord clips;
- A carrying bag or case;
- One (1) set of operating and maintenance instructions in English, including a list of the aerosol can types tested with the holder.
- Twelve(12) aerosol cans for hornet and wasp mitigation of at least 400ml

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 9 of 18

4.9 Technical Particulars


4.9.1 The aerosol can holder shall have the technical particulars shown in Table 1 below.

Table 1: Technical particulars of Aerosol Can Holder for Live-Line Work

Parameter	Description
Voltage classes of application	66 kV, 132 kV and 220 kV (mounted on a stick with the required insulating length)
Attachment	Universal end fitting (IEC 60832)
Insulating material	Epoxy-glass FRP or high-impact UV-stabilised polymer
Dielectric strength of polymer parts	Not less than 15 kV/mm
Dielectric withstand of insulating parts	100 kV (rms, 50 Hz) per 300 mm, 1 minute
Can size accepted	400 mL (14 oz); diameter [50 mm to 70 mm]; height up to [260 mm]
Can retaining force	Not less than [100 N]
Actuating force	Not more than [40 N]
Nozzle angle adjustment	At least [0° to 90°], locked positively
Actuator endurance	Not less than [10,000] cycles
Weight without can	1.0 kg maximum
Overall length	400 mm maximum
Operating temperature	-5 °C to +50 °C
Storage temperature	-5 °C to +60 °C
Humidity range (relative humidity)	20% to 96%, non-condensing
Type test	According to IEC 60832, IEC 61477 and IEEE 978

5. TEST REQUIREMENTS

- 5.1 The aerosol can holder shall be inspected and tested in accordance with IEC 60832, IEC 60855-1, IEC 61477, IEC 60060-1, IEC 60068.
- 5.2 Copies of previous test reports issued by the manufacturer or a third-party testing laboratory that is accredited to ISO/IEC 17025:2005 or 17025:2017, confirming the dielectric and mechanical performance and compliance of the holder offered, shall be submitted with the offer for evaluation (all in English language).
- 5.3 Copies of test reports for the holder offered shall be submitted, covering the following tests:

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 10 of 18

a) Routine tests (on every unit)

- i. Visual and dimensional inspection
- ii. Dielectric withstand test of the insulating parts
- iii. Fit check of the universal end fitting with a go/no-go gauge
- iv. Functional test of the actuator, spring return and lock
- v. Can retention check
- vi. Marking and durability of markings

b) Type tests

- i. Dielectric tests on the insulating parts: power-frequency withstand, and moisture absorption after wet conditioning
- ii. Material tests on polymer parts: dielectric strength and comparative tracking index
- iii. Mechanical tests: bending and torsion of the arm; tension and torsion of the universal end fitting
- iv. Can retention test under axial load, vibration and shock
- v. Drop and impact tests, including the carrying case
- vi. Actuator endurance test of not less than [10,000] cycles
- vii. Environmental tests: temperature, humidity, UV and weathering (IEC 60068, ISO 4892-2) and resistance to the solvents and propellants in approved spray products

c) Functional tests on the holder that shall include:


- i. Spray test with a can of an approved product, showing that the spray reaches the target at the stated distance
- ii. Leak and discharge test, showing no spray when the actuator is locked or released
- iii. Fitting and removal of the holder and the can by a lineman wearing gloves
- iv. Compatibility with the universal end fitting of KPLC live-line sticks

6. MARKING AND PACKING

6.1 Marking

The following information shall be marked legibly and permanently on each holder:

- i. The manufacturer's name or trade mark;
- ii. Maximum voltage of use (kV) and the minimum effective insulating length of the stick to be used;
- iii. Model number;
- iv. Serial number;
- v. Date of manufacture and date of last dielectric test;
- vi. A warning label, in English and Kiswahili, to use only spray products approved by KPLC;
- vii. Letters "Property of Kenya Power & Lighting Plc".

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 11 of 18

6.2 Packing

- 6.2.1 The holder and its accessories shall be packed in a carrying case or bag so as to protect them from damage and entry of moisture during transportation, handling and storage.
- 6.2.2 The carrying case shall be shock proof and impact resistant and shall be able to withstand a fall of the packed holder.

7. WARRANTY

- 7.1 The aerosol can holder shall be backed by a minimum of 12-months warranty period from the date of delivery to KPLC stores.
- 7.2 Technical support, and the availability of spare parts (straps, springs, pins, cord clips), shall be guaranteed for a period of not less than 5 years. Technical support shall be provided free of charge for not less than 36 months.
- 7.3 The Bidder shall submit a clause-by-clause statement of compliance with the specification (GTP) together with copies of the manufacturer's catalogues, brochures, technical data and proven test reports, all in English, for evaluation, according to Appendix C1 of this Specification. The manufacturer's type reference/designation of the item offered shall be indicated.
- 7.4 In the case of tender award, technical details for the aerosol can holder shall be submitted to Kenya Power for approval before manufacture commences, according to Appendix C2 of this Specification.


8. TRAINING

8.1 Training at the manufacturer's premises

- 8.1.1 The successful bidder/manufacturer shall arrange to conduct a Factory Acceptance Test for the manufactured holders. The Factory Acceptance Test shall include training on the holder for [two (2)] KPLC engineers/technicians. At least one (1) of the engineers/technicians shall be live-line users.
- 8.1.2 The training shall include theory followed by practical demonstrations on fitting the holder to a live-line stick, loading and replacing the can, adjusting the nozzle, and remote operation on a live line.
- 8.1.3 The manufacturer shall plan adequate time for the training, which shall be conducted by the manufacturer's expert.
- 8.1.4 The training shall be deemed successful once the engineers/technicians are able to inspect, test and use the holder safely.
- 8.1.5 The manufacturer shall meet all the costs of the factory training.

8.2 Local Training


- 8.2.1 Following delivery of the holders, the manufacturer shall conduct training in Nairobi, Kenya. The training shall be conducted in one session of [20] KPLC engineers/technicians and shall last at least [one (1) day].
- 8.2.2 The training shall include theory on features and how the equipment works, safe live-line working practice, routine care, dielectric testing, and the safe selection and handling of approved spray

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 12 of 18

products, followed by practical demonstrations. All steps shall be exhaustively explained and demonstrated.

- 8.2.3 The training shall be considered to have been successful once the engineers/technicians are able to completely inspect, test and use the holder.
- 8.2.4 The supplier shall meet all the costs for conducting the local training, including local accommodation and transport for their training staff. The supplier shall provide all the training materials including notes.

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 13 of 18

APPENDICES

A: TESTS AND INSPECTION (Normative)


- A.1 It shall be the responsibility of the supplier to test or to have all the relevant tests performed on the aerosol can holder.
- A.2 Copies of previous test reports issued by the manufacturer or a third-party testing laboratory that is accredited to ISO/IEC 17025:2005 or 17025:2017 shall be submitted with the tender for the purpose of technical evaluation. A copy of the accreditation certificate for the testing laboratory shall also be submitted with the tender (all in English language). Any translations of certificates and test reports into English language shall be signed and stamped by the Testing Authority.
- A.3 Test certificates and calibration certificates shall be submitted by the supplier to KPLC for approval before supply/delivery.
- A.4 On receipt of the holders, Kenya Power will inspect the items and may perform relevant tests (including dielectric tests of the insulating parts) in order to verify compliance with the specification. The supplier shall replace without charge to Kenya Power any unit that upon test or use fails to meet any or all of the requirements in the specification.

B: QUALITY MANAGEMENT SYSTEM (Normative)

- B.1 The supplier shall submit a Quality Assurance Plan (QAP) that will be used to ensure that the physical properties, tests and documentation of the holder will fulfil the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfil the requirements of ISO 9001:2015.
- B.2 The manufacturer's Declaration of Conformity to applicable standards and copies of quality management certifications, including a copy of valid and relevant ISO 9001:2015 certificate, shall be submitted with the tender for evaluation.
- B.3 The bidder shall indicate the delivery time of the equipment. A detailed list and contact addresses (including e-mail) of the manufacturer's previous customers for similar live-line equipment sold shall be submitted with the tender for evaluation.

C: TECHNICAL DOCUMENTATION (Normative)


- C.1 The bidder shall submit its tender complete with technical documents for tender evaluation. The technical documents to be submitted (all in English language) shall include:
- Fully filled clause-by-clause Guaranteed Technical Particulars (GTP) signed by the manufacturer, as indicated in Appendix D of this Specification;
 - Copies of the manufacturer's catalogues, brochures, drawings giving all relevant dimensions and technical data;
 - Records for previous projects, local or foreign, for the items;
 - Details of manufacturing capacity and the manufacturer's experience;
 - Copies of required test reports of a testing laboratory accredited to ISO/IEC 17025;
 - Copy of accreditation certificate to ISO/IEC 17025 for the testing laboratory;

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 14 of 18

- g) Manufacturer's letter of authorisation, ISO 9001 certificate, and other technical documents required in the tender;
- h) Manufacturer's warranty and guarantee, subject to 12 months from date of delivery of items to KPLC stores;
- i) Operational and service manual for the items.
- C.2 The successful bidder (supplier) shall submit the following documents/details to The Kenya Power & Lighting Company for approval before manufacture:
- a) Fully filled clause-by-clause GTP stamped and signed by the manufacturer, as indicated in Appendix D;
- b) Drawings of the holder to be manufactured for KPLC;
- c) Product operation manuals and brochures;
- d) Quality assurance plan (QAP) used to ensure that the design, material, workmanship, tests, service capability, maintenance and documentation will fulfil the requirements stated in the contract documents, standards, specifications and regulations. The QAP shall be based on and include relevant parts to fulfil the requirements of ISO 9001:2015;
- e) Marking details and method to be used in marking the holder;
- f) All documentation necessary for safety of the equipment;
- g) Packaging details (including packaging materials).
- C.3 The supplier shall submit recommendations for use, care, storage, and routine inspection and in-service dielectric testing procedures, all in the English language, during delivery of the holders to KPLC stores.
- C.4 Sample photos;



Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 15 of 18


D: GUARANTEED TECHNICAL PARTICULARS (Normative)

To be filled and signed by the bidder, Agent, Manufacturer and submitted together with relevant copies of the Manufacturer's catalogues, brochures, drawings, technical data, sales records for previous five years, four customer reference letters, details of supplier's capacity and experience, and copies of complete type test certificates and test reports for tender evaluation, all in English language.

Tender No.


Bidder's name and address

Clause number	Requirement	KPLC Requirement	Bidder's offer
	Manufacturer's name and address	State	
	Country of manufacture	State	
	Name and model number	State	
1.0	Scope	State	
2.0	Normative references	State	
3.0	Definitions and abbreviations	State	
4.0	Requirements		
4.1	Service conditions	State	
4.2	Design and construction		
4.2.1	Standards of design and manufacture	State	
4.2.2	Main components of the holder	State	
4.2.3	Universal attachment compatibility	State	
4.2.4	Materials and corrosion protection of metal parts	State	
4.2.5	Overall length and insulating section length	State	
4.3	Holder body and insulating parts		
4.3.1	Body and arm material; dielectric strength and CTI of polymer	State	
4.3.2	Dielectric withstand of insulating parts	State	
4.3.3	Surface finish, UV and chemical resistance, moisture absorption	State	
4.3.4	Operating cord: type, diameter and length	State	
4.4	Can holding arrangement		
4.4.1	Can sizes accepted	State	

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19

	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 16 of 18

Clause number	Requirement	KPLC Requirement	Bidder's offer
4.4.2	Retaining strap/clamp, secondary retention and retaining force	State	
4.4.3	Tool-free can replacement	State	
4.5	Remote actuation		
4.5.1	Actuator type and actuating force	State	
4.5.2	Spring return, lock or safety pin	State	
4.5.3	Cord guides or clips	State	
4.5.4	Actuator endurance (cycles)	State	
4.6	Nozzle positioning		
4.6.1	Nozzle angle range and locking	State	
4.6.2	Extension nozzle provision and spray guard	State	
4.7	Weight and overall dimensions	State	
4.8	Accessories supplied	State	
4.9	Table 1 technical particulars		
4.9.1	Dielectric withstand of insulating parts (100 kV per 300 mm)	State	
4.9.2	Can size accepted (400 mL; diameter and height)	State	
4.9.3	Can retaining force	State	
4.9.4	Actuating force	State	
4.9.5	Nozzle angle adjustment	State	
4.9.6	Weight without can	State	
4.9.7	Operating temperature (-5 °C to +50 °C)	State	
5.0	Test requirements		
5.1	Manufacturer's capabilities of inspection and testing	State	
5.2	Copies of previous test reports; accreditation certificate and scope	Attach	
5.3	Copies of routine, type and functional test reports	Attach	
6.0	Marking and packing		
6.1	Marking	Specify	
6.2	Packing	Specify	

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19



TITLE:

AEROSOL CAN HOLDER FOR LIVE-LINE WORK

Doc. No.

KP1/7B.2/TSM/ST/09/013-1

Issue No.

1

Revision No.

0

Date of Issue

2026-10-19

Page 17 of 18

Clause number	Requirement	KPLC Requirement	Bidder's offer
7.0	Warranty: state duration	State	
7.1	Minimum 12-months factory warranty	State	
7.2	Technical support (36 months) and spare parts availability (5 years)	State	
7.3	Clause-by-clause statement of compliance with supporting documents	State	
7.4	Technical details for KPLC approval before manufacture	State	
8.0	Training		
8.1	Training at manufacturer's premises ([2] engineers/technicians)	State compliance	
8.2	Local training ([20] engineers/technicians, at least [1] day)	State compliance	
A	Test and inspection		
A.1	Responsibility of carrying out tests	State	
A.2	Copies of type test reports submitted with tender	Provide	
A.3	Test and calibration certificates for approval before delivery	Provide	
A.4	Inspection at the stores and replacement of rejected items	State	
B	Quality management system		
B.1	Quality Assurance Plan	Provide	
B.2	Copy of ISO 9001:2015 certificate	Provide	
B.3	Manufacturer's experience and list of previous customers	Provide	
C	Technical documentation		
C.1	Documents submitted with tender	Provide	
C.2	Documents to be submitted for approval before manufacture	Provide	
C.3	Documents to be submitted during delivery at the store	Provide	
C.4	Statement of deviations, if any, and supporting documents	State deviations	

Head of Section: Sub-transmission, Central office

Head of Department: Transmission, Central office

Signed:

Signed:

Date: 2026-10-19

Date: 2026-10-19


	TITLE: AEROSOL CAN HOLDER FOR LIVE-LINE WORK	Doc. No.	KP1/7B.2/TSM/ST/09/013-1
		Issue No.	1
		Revision No.	0
		Date of Issue	2026-10-19
			Page 18 of 18

NOTE:

- 1) Bidders shall give full details of the items on offer as per the specification and applicable standards. The details provided shall conform to the test reports and their certificates, as well as labelled drawings complete with dimensions, catalogues and/or brochures for the purpose of tender evaluation.
- 2) Bidders should note that the above Guaranteed Technical Particulars schedules must be fully completed and submitted with the bid. Wherever there is conflict between the GTPs and the clauses in the specification, the clauses in the specification take precedence. Failure to complete the schedules shall lead to rejection of the bid.
- 3) Guaranteed values shall be specified. Words like 'agreed', 'confirmed', 'As per KPLC specifications', etc. shall not be accepted and shall be considered non-responsive.

.....*

Manufacturer's Name, Signature, Stamp and Date

Head of Section: Sub-transmission, Central office	Head of Department: Transmission, Central office
Signed: 	Signed: 
Date: 2026-10-19	Date: 2026-10-19