Kenya Power

Central Office – *P.O. Box 30099, Nairobi, Kenya*
Telephone – 254-02-3201000
Fax No. 254-02-3514485
StimaPlaza, Kolobot Road
Nairobi, Kenya

Our Ref: KP1/9A.3/OT/04/26-27/JN/ri *17th November, 2026*

TO: ALL BIDDERS

RE: ADDENDUM NO II- SUPPLY OF LIVE LINE RUBBER GOODS - TENDER NO. KP1/9A.3/OT/04/26-27

Please refer to the above tender.

We Make the Following Amendments to the above Principal Tender Document *(Hereinafter abbreviated as the PTD)* For the Supply of Live Line Rubber Goods.

1. RELATIONSHIP WITH THE PRINCIPAL TENDER DOCUMENT

Save where expressly amended by the terms of this Addendum, the PTD shall continue to be in full force and effect. The provisions of this Addendum shall be deemed to have been incorporated in and shall be read and construed as part of the PTD.

2. CLARIFICATIONS

The following clarifications have been addressed as below:

	BIDDER'S QUERIES	KPLC RESPONSE.
1	Rubber Gloves Class 3 Size 9.5- Specification states that Rubber insulating gloves shall be made so as to be used for works at voltages up to 36kv phase to phase. Kindly clarify if you require class 4 rubber gloves because they work at voltages up to 36kv.	The tender is for Rubber Gloves Class 3 Size 9.5. Maximum AC use voltage 26.5 kV AC proof-test voltage 30 kV AC withstand-test voltage 30 kV
2	By-pass Jumper Flexible Class 2 and Class 4 -Specification states that; The jumper clamps shall be different types and sizes based on the voltage ratings namely 1. Small 15kv clamp with 150mm handle below the hand guard 2. Small 15kv clamp with 190mm handle below the hand guard 3. 35kv clamp with 220m handle below the hand guard.	With reference to your clarification request on By-pass Jumper Flexible, please be guided as follows: The clamp specifications shall be allocated according to the intended voltage rating of the bypass jumper as indicated below:

Clamp specification	Voltage rating	Applicable class
Small clamp,	15 kV	Class 2

<table>
<tr><td></td><td>Kindly clarify based on voltage ratings, which one is class 2 and which is class 4.</td><td>
<table>
<tr><td>150 mm handle below hand guard</td><td></td><td></td></tr>
<tr><td>Small clamp, 190 mm handle below hand guard</td><td>15 kV</td><td>Class 2</td></tr>
<tr><td>35 kV clamp, 220 mm handle below hand guard</td><td>35 kV</td><td>Class 4</td></tr>
</table>

Therefore, both 15 kV clamp variations shall be supplied under Class 2, while the 35 kV clamp shall be supplied under Class 4.

The specified handle dimensions shall be maintained as indicated in the tender specifications. The supplier shall also provide the relevant manufacturer's technical data and test certificates demonstrating compliance with the applicable electrical voltage ratings and safety requirements.

All other requirements of the tender specifications remain unchanged.</td></tr>
<tr><td>3</td><td>Kindly share specs for Anti-rust lubricant, wire rolling sticks, and webbing sling(endless)</td><td>Shared separately.</td></tr>
</table>

All other terms and conditions remain the same.

Yours faithfully,

FOR: THE KENYA POWER & LIGHTING COMPANY PLC

HAROUN OTIENO

AG. GENERAL MANAGER, SUPPLY CHAIN & LOGISTICS